

# Transformer 2

POWER TRANSFORMER DEPARTMENT



PITTSFIELD, MASS.

Date of Test May 1975

## REPORT OF TEST ON TRANSFORMERS

Purchaser [REDACTED]

RATING **\*\*120000/160000/200000(Out put)KVA**

	H - Winding	X - Winding	Y - Winding
Volts	223000GRY/128750	69000GRY/39840	13800
Kva	**	**	29000//48300

Taps as per attached Nameplate: 268275

### CHARACTERISTICS

Losses, efficiencies and regulations are based on wattmeter measurements and, unless otherwise stated, on normal rating. For three phase transformers the resistances given are the sum of the three phases.

	Resistance at 85C			NO LOAD LOSS WATTS AT 100% VOLTAGE	% EXCIT. CURRENT AT 100% VOLTAGE	223 GRY Kv		223 GRY Kv		69 GRY Kv	
	H	X	Y			To	To	To	To	To	To
	At	At	At			At	At	At	At	At	At
	1.270	.1544	.1736	96850	0.553	230500	5.99	133060	10.26	147290	13.70
AVERAGE					.6		6.20		-		-
GUARANTEE											
Total Loss Watts at 85C				98000		327350		229910		244140	
				AVERAGE		335000					
				GUARANTEE							
	EFFICIENCIES AT 85C 100% P-F					REGULATION AT 85C					
	Load	Full Load	% Load	1/2 Load	1/4 Load		100% P-F	90% P-F	80% P-F	70% P-F	
AVERAGE		99.73	99.75	99.74	99.63	AVERAGE	0.371	2.93	3.85		
GUARANTEE		99.72	99.74	99.74	99.63	GUARANTEE	0.4	-	4.0		

### TEMPERATURE RISE (Serial No. \* )

Average ultimate temperature rise in deg C corrected to instant of shutdown

	H - Winding		X - Winding		Y - Winding		Method of cooling:	
Winding Connection	223000	v.	61275	v.	13800	v.	OA	
MVA   Amp.	120	311	120	1116	29	1213	Top oil rise:	56.4 C
Rise Test   Guar.	58.7C	65 C	59.3C	65 C	62.2C	65 C	Ambient	25.0 C
Winding Temp. Ind.	deg C		deg C		deg C			
Winding Connection	223000	v.	61275	v.	13800	v.	FOA	
MVA   Amp.	200	518	200	1674	200	2030	Top oil rise:	32.7 C
Rise Test   Guar.	59.0C	65 C	61.5 C	65 C	57.1 C	65 C	Ambient	25.0 C
Winding Temp. Ind.	deg C		deg C		deg C			

### DIELECTRIC TESTS

APPLIED POTENTIAL TEST	VOLTAGE OF WINDING TESTED	TEST VOLTAGE APPLIED	DURATION IN SECONDS
	Voltage applied to each winding in turn with all other windings connected to core and ground. Line terminal to ground	H X Y	50000 50000 34000

Induced voltage test: 305KV/5V associated voltage on each full winding at 429 cycles per second for 7200 cycles

Remarks: \*Temperature values are based on design data obtained from thermally similar transformers.

(Continued on Page -2-)

POWER TRANSFORMER DEPARTMENT  
**GENERAL ELECTRIC**  
 PITTSFIELD, MASS.

Additional Test Data

Additional Resistances at 85°C

Connection	Test
75900Y	.1843
62100Y Ser.	.1855
Exc. U. Wdg.	.9654

Insulation Power Factor Tests

H-X - Grd.	Y - Grd.	Temp. °C
0.23	0.23	43.2

Voltage Ratios

Connection	Calculated	Phase 1	Phase 2	Phase 3
223000-75965	2.9356	2.9352	2.9373	2.9385
223000-75550	2.9517	2.9524	2.9545	2.9562
223000-75125	2.9684	2.9671	2.9692	2.9708
223000-74705	2.9851	2.9849	2.9870	2.9888
223000-74280	3.0021	3.0010	3.0032	3.0050
223000-73850	3.0196	3.0194	3.0216	3.0234
223000-73420	3.0373	3.0361	3.0382	3.0401
223000-72985	3.0554	3.0551	3.0573	3.0591
223000-72550	3.0737	3.0725	3.0746	3.0765
223000-72110	3.0925	3.0920	3.0942	3.0961
223000-71670	3.1115	3.1101	3.1123	3.1142
223000-71225	3.1309	3.1305	3.1326	3.1346
223000-70780	3.1506	3.1502	3.1526	3.1547
223000-70330	3.1708	3.1703	3.1725	3.1744
223000-69880	3.1912	3.1898	3.1920	3.1940
223000-69425	3.2121	3.2117	3.2140	3.2159
223000-69000	3.2319	3.2329	3.2352	3.2371
223000-68510	3.2550	3.2545	3.2568	3.2587
223000-68050	3.2770	3.2757	3.2779	3.2799
223000-61275	3.6393	3.6378	3.6415	3.6430
223000-13800	16.1594	16.1748	16.1796	16.1960
69000-13800	5.0000	5.0117	5.0086	5.0117

Polarity and phase relation checked out OK.

To check the calibration of the winding temperature indicators the following information may be used.

CT	Current To Apply For 30 Minutes	Terminals	Rise Over 25°C Oil	Resistance (Ohms)
A	32.4	X1 - Xo G	38.8	None
B	32.0	X2 - Xo G	39.1	.070
C	30.3	X3 - Xo G	38.1	.170

These values will be approximately 3°C higher in 0°C top oil and 3°C lower in 50°C top oil. The resistors should be in place for all tests.

# AUTO TRANSFORMERS

DATE 8-27-76  
 AIR TEMP. 54°F TOP OIL TEMP.  
 WEATHER Partly Cloudy % HUMIDITY 70

MFR. <u>G-F</u>	TYPE <u>30</u>	FORM	CLASS <u>0415A150A</u>
KVA <u>200,000</u>	MFR. <u>G-F</u>	TYPE <u>U</u>	FORM <u>HT69</u>
HIGH SIDE KV <u>223</u> Y <input checked="" type="checkbox"/> Δ <input type="checkbox"/>	BUSHINGS <u>G-F</u>	TYPE <u>U</u>	FORM <u>HT69</u>
LOW SIDE KV <u>69</u> Y <input checked="" type="checkbox"/> Δ <input type="checkbox"/>	BUSHINGS <u>G-F</u>	TYPE <u>U</u>	FORM <u>HT69</u>
TERT. SIDE KV <u>13.8</u> Y <input type="checkbox"/> Δ <input checked="" type="checkbox"/>	BUSHINGS <u>G-F</u>	TYPE <u>U</u>	FORM <u>HT69</u>

COPIES TO: \_\_\_\_\_ DATE LAST TEST 11/1/75 TEST SHEET NO. \_\_\_\_\_

## OVERALL TESTS

TEST	TEST CONNECTIONS			TEST KV	EQUIVALENT 10 KV READINGS						% POWER FACTOR		KEY TO INSULATION RATING G= GOOD D= DETERIORATED I= INVESTIGATE B= BAD (REMOVE OR RECONDITION)	INSULATION RATING
	WINDING ENERGIZED	WINDING GROUNDED	WINDING GUARDED		MILLIAMPERES			WATTS			MEASURED	COR. 20°C		
					METER READING	MULTIPLIER	MILLI-AMPERES	METER READING	MULTIPLIER	WATTS				
1	HIGH LOW	TERT.		10	93	2	186	6	1	6	---	---		---
2	HIGH LOW		TERT.	10	87	2	174	5.5	1	5.5	.316	---	CH	---
3	TERT.	HIGH LOW		10	79	1	79	7.5	2	1.5	---	---		---
4	TERT.		HIGH LOW	10	66	1	66	7	2	1.2	.217	---	CT	---
CALCULATED RESULTS					---	---	12	---	---	.5	.41	---	CHT (TEST 1 MINUS TEST 2)	---
					---	---	12	---	---	.1	---	---	ITEST 3 MINUS TEST 4)*	---


\*CURRENT AND WATTS SHOULD COMPARE WITH THOSE FOR CHT

## BUSHING TESTS

LINE NO.	BUSH NO.	PHASE	TEST KV	EQUIVALENT 10KV READINGS						% POWER FACTOR		COLLAR TESTS (WATTS / CURRENT)		INSULATION RATING
				MICROAMPERES			WATTS			MEASURED	COR. 20°C	TOP		
				METER READING	MULTIPLIER	MICRO-AMPERES	METER READING	MULTIPLIER	WATTS					
HIGH	1	H <sub>1</sub>	10	67	20	1340	6	.01	.66	.407				
	2	H <sub>2</sub>	10	67	20	1340	3	.01	.03	.232				
	3	H <sub>3</sub>	10	67	20	1340	3	.01	.03	.232				
LOW	4	X	7	64	20	1280	5	.01	.05	.29				
	5	Y <sub>1</sub>	7	61	20	1220	5	.01	.05	.29				
	6	Y <sub>2</sub>	7	63	20	1260	4	.01	.04	.217				
TERT.	7	N	10	83	20	1660	6	.01	.06	.210				
	8	Y <sub>1</sub>	10	85	20	1700	7	.01	.07	.113				
	9	Y <sub>2</sub>	10	22	1	2.2	3	.01	.03	.273				
10	Y <sub>3</sub>	10	20	1	2.0	7.5	.01	.05	.250					
11	N													
12			10	21	1	2.1								
13			10	26	1	2.6								
14	OIL SAMPLE		10	35	1	35								

N = NEUTRAL

## DIAGRAM



INSULATION TESTS  
MISCELLANEOUS EQUIPMENT

(METERS, ETC.)

DATE 8-27-76

AIR TEMP. 50°F OIL TEMP.

WEATHER / - - - - - % HUM. 70

DATE LAST TEST 10/1/71

LAST TEST SHEET NO.



LINE NO.	TEST KV	EQUIVALENT 10 KV READINGS					% POWER FACTOR		INSULATION RATING
		MICROAMPERES			WATTS		MEASURED	COR 20°C	
		METER READING	MULTIPLIER	MICRO-AMPERES	METER READING	MULTIPLIER			
1	512	1.5	10	15	1.5	1.5	1.5	1.5	MODEL 9211A VIA T.D.
2	190KV	1.5	10	15	1.5	1.5	1.5	1.5	1370 1110K 190
3	10	20	10	200	1	100	1.1		
4	10	20	10	200	10	600	0.0		
5	10	20	10	200	1.2	81	0.15		
6									
7	105	1.5	10	150	1.2	5.1	1.1	1.1	APPROX 100% 191 10 1000
8		0.5	10	50	1.2				
9	10	11	10	110	6.9	607	0.95		
10	10	11	10	110	4.8	607	0.96		
11	10	11	10	110	5.3	607	0.96		
12									
13	105	1.5	10	150	1.2	5.1	1.1	1.1	STATION 100% 191 10 1000
14	MODEL 9211A	3	10	30	1.5	15	1.1	1.1	1970
15	10	15	10	150	7.5	607	0.96		
16	10	17.5	10	175	7.6	607	0.97		
17	10	17	10	170	7.4	607	0.95		
18									
19	10	13	10	130	7.5	607	0.95		
20	10	13	10	130	7.5	607	0.95		
21	10	13	10	130	15	607	0.96		
22	10	13	10	130	15	607	0.93		
23	10	12	10	120	8	607	0.96		
24	10	12	10	120	8	607	0.96		
25	10	12	10	120	6	607	0.92		
26	10	13	10	130	9	607	0.95		
27	10	13	10	130	8	607	0.94		
28	10	13	10	130	15	607	0.93		
29	10	12.5	10	125	6	607	0.93		

REMARKS

DOBLE TEST

230KV-69KV 200MVA TRANSFORMER

(2)



# AUTO TRANSFORMERS

DATE 2-11-76  
 AIR TEMP. 16°F TOP OIL TEMP. 21°C  
 WEATHER Clear % HUMIDITY 81%

MFR. C-F TYPE 3d FORM CLASS 0A/FA/FA  
 KVA 200,000 MFR TYPE FORM CLASS [REDACTED] KV AMP. YEAR  
 HIGH SIDE KV 273 Y  Δ   
 LOW SIDE KV 69 Y  Δ   
 TERT. SIDE KV 13.8 Y  Δ   
 COPIES TO: DATE LAST TEST INITIAL LAST SHEET NO. INITIAL

## OVERALL TESTS

TEST	TEST CONNECTIONS			TEST KV	EQUIVALENT 10 KV READINGS					% POWER FACTOR		KEY TO INSULATION RATING G • GOOD D • DETERIORATED I • INVESTIGATE B • BAD (REMOVE OR RECONDITION)	INSULATION RATING	
	WINDING ENERGIZED	WINDING GROUNDED	WINDING GUARDED		MILLIAMPERES			WATTS		MEASURED	COR. 20°C			
					METER READING	MULTIPLIER	MILLI-AMPERES	METER READING	MULTIPLIER					WATTS
1	HIGH LOW	TERT.		10	96	2	192	6	1	6	---	---		
2	HIGH LOW		TERT.	10	90	2	180	5.5	1	5.5	.30	.27	CH	WG
3	TERT.	HIGH LOW		10	80	1	80	10	.2	2.0	---	---		
4	TERT.		HIGH LOW	10	65	1	65	9	.2	1.8	.26	.23	CH	WG
CALCULATED RESULTS					---	---	12	---	---	.5	.41	.369	CH (TEST 1 MINUS TEST 2)	WG
					---	---	12	---	---	.2	---	---	(TEST 3 MINUS TEST 4)*	---


\*CURRENT AND WATTS SHOULD COMPARE WITH THOSE FOR C<sub>WT</sub>

## BUSHING TESTS

LINE NO.	BUSH. NO.	PHASE	TEST KV	EQUIVALENT 10KV READINGS					% POWER FACTOR		COLLAR TESTS (WATTS / CURRENT)			INSULATION RATING	
				METER READING	MULTIPLIER	MICRO-AMPERES	METER READING	MULTIPLIER	WATTS	MEASURED	COR. 20°C	TOP			
HIGH	1	H <sub>1</sub>	10	66	20	1320	3.5	.01	.035	.26				G	
	2	H <sub>2</sub>	10	65	20	1300	4	.01	.04	.30				G	
	3	H <sub>3</sub>	10	67	20	1340	4	.01	.04	.29				G	
	4	X <sub>1</sub>	10	SEE MISC. SHEET											
POO	5	X <sub>2</sub>	10	62	20	1240	5	.01	.05	.46				G	
	6	X <sub>3</sub>	10	SEE MISC. SHEET											
	7	H <sub>1</sub> X <sub>2</sub>	10	84	20	1680	9	.01	.09	.53				G	
TERT.	8	Y <sub>1</sub>	10	21	.1	2.1	3	.02	.06	.30				G	
	9	Y <sub>2</sub>	10	20	.1	2.0	3	.02	.06	.30				G	
	10	Y <sub>3</sub>	10	20	.1	2.0	3	.02	.06	.30				G	
	11	X	CIT. TAP TEST ON X WINDING FERRITE UST END												
	12		8	67	1	67					X <sub>1</sub>	X <sub>2</sub>	X <sub>3</sub>		
	13		8	58	1	58					X <sub>2</sub>	X <sub>3</sub>	X <sub>1</sub>		
	14	OIL SAMPLE	8	83	2	166					X <sub>3</sub>	OIL TEMP	°K <sub>2</sub>		

N = NEUTRAL

### DIAGRAM



INSULATION TESTS  
MISCELLANEOUS EQUIPMENT

DATE 2-11-76  
 AIR TEMP. 76°F OIL TEMP. 74°C  
 WEATHER Cloudy % HUM. 51%  
 DATE LAST TEST  
 LAST TEST SHEET NO.

LINE NO.	TEST KV	EQUIVALENT 10 KV READINGS						% POWER FACTOR MEASURED
		MICROAMPERES			WATTS			
		METER READING	MULTIPLIER	MICRO-AMPERES	METER READING	MULTIPLIER	WATTS	
X1	7	60	20	1200	9	.02	.18	1.5
2	8	60	20	1200	3.5	.01	.035	.30
3								
4								
X2	7	61	20	1220	8	.02	.16	1.31
6	8	62	20	1240	4	.01	.04	.325
7								
8								
X3	7	61	20	1220	8	.02	.16	1.31
10	8	60	20	1200	3.5	.01	.035	.30
11								
12								
13								
14		CITATION TEST ON H WINDING						
15								ENERGIZE
16	10	24	1	24				H1 R
17	10	24	1	24				H2
18	10	27	1	27				H3
19								
20								
21								
22								
23								
24								
25								
26								
27								
28								
29								

REMARKS

[REDACTED REMARKS]



# AUTO TRANSFORMERS

BELMONT, MASS.  
FORM MH-AT175

DATE 1-23-76  
 AIR TEMP. 62 TOP OIL TEMP. 20°C  
 WEATHER Clear % HUMIDITY 63  
 FORM CLASS DA/FA/FOA

KVA	MFR	TYPE	FORM	CLASS	KV	AMP.	YEAR
<u>120-160-200</u>	<u>GE</u>	<u>U</u>			<u>146</u>	<u>800</u>	<u>1974</u>
HIGH SIDE KV <u>223 Y □ Δ □</u>	<u>GE</u>	<u>U</u>			<u>44</u>	<u>2000</u>	<u>1975</u>
LOW SIDE KV <u>69 Y □ Δ □</u>	<u>GE</u>	<u>U</u>	<u>AT-69</u>		<u>16</u>	<u>3000</u>	<u>1974</u>
TERT. SIDE KV <u>13.8 Y □ Δ □</u>	<u>GE</u>	<u>U</u>	<u>AT-23</u>				

COPIES TO:  
X0-GE Type U CLASS 1-25. CAT # 78522BB 64 Amp 100/1200 10KV 1974  
FT TAP 2 2.105 OVER ALL TESTS

TEST	TEST CONNECTIONS			TEST KV	EQUIVALENT 10KV READINGS						% POWER FACTOR		KEY TO INSULATION RATING G- GOOD D- DETERIORATED I- INVESTIGATE B- BAD (REMOVE OR RECONDITION)	INSULATION RATING
	WINDING ENERGIZED	WINDING GROUNDED	WINDING GUARDED		MICROAMPERES			WATTS			MEASURED	COR. 20°C		
					METER READING	MULTIPLIER	MICRO-AMPERES	METER READING	MULTIPLIER	WATTS				
1	HIGH LOW		TERT.	10	94.5	2	189.	5.25	1	5.25	---	---		
2	HIGH LOW		TERT.	10	88.5	2	177.	5.	1	5.	.29	.29	CH	WG
3		HIGH LOW	TERT.	10	81.	1	81	10.25	2	205	---	---		
4	TERT.		HIGH LOW	10	88.75	1	88.75	9.25	2	185	.27	.27	CT	WG
CALCULATED RESULTS							12.			.25	.21	.21	CH (TEST 1 MINUS TEST 2)	WG
							17.25			.2			(TEST 3 MINUS TEST 4)	


## BUSHING TESTS M=1.

LINE NO.	BUSH NO.	PHASE	TEST KV	EQUIVALENT 10KV READINGS						% POWER FACTOR		COLLAR TESTS (WATTS/CURRENT)		INSULATION RATING
				MICROAMPERES			WATTS			MEASURED	COR. 20°C	TOP		
				METER READING	MULTIPLIER	MICRO-AMPERES	METER READING	MULTIPLIER	WATTS					
1	H1	A	10	69	20	1380	2.5	.01	.025	.18	.18	.03	150	G
2	H2	B	10	69	20	1340	2.5	.01	.025	.18	.18	.03	150	G
3	H3	C	10	67	20	1340	2.5	.01	.025	.18	.18	.03	150	G
4	X1	A	10	60.5	20	1210	2.5	.01	.025	.21	.21	.02	130	G
5	X2	B	10	60.5	20	1210	2.5	.01	.025	.21	.21	.01	130	G
6	X3	C	10	60.5	20	1210	2.5	.01	.025	.21	.21	.02	130	G
7	N													
8	T1	A	10	23	1	2.3	4	.02	.08	.35	.35	.01	130	G
9	T2	B	10	21.5	1	2.15	3.5	.02	.07	.33	.33	.01	130	G
10	T3	C	10	21.5	1	2.15	3.5	.02	.07	.33	.33	.01	130	G
11	X0		10	81.5	20	1630	4.5	.01	.045	.27	.27	.01	110	G
12														
13			10	79	10	790	5	.002	.01	.12				XG
14	OIL SAMPLE	MAIN	10	79	10	790	4	.002	.003	.1				XG


**DIAGRAM**  
 exciting current test



	CI	%PF	REMARKS	CI ACT
H1	379	.33		365
2	364	.32		355
3	351	.30		355
X1	334	.27		3
2	330	.26	20	320
3	330	.26		320
T1	565	.24		609
2	565	.27		569
3	607	.31		569
X0	449	.37		431

H1-10KV 27 x 2 = 54 millia  
 H2-10KV 98 x 2 = 3  
 H3-10KV 26 x 2 = 52



Handwriting practice lines consisting of ten horizontal lines.







5 NOTE FOR REF PTS SEE




SKETCH "B" (1) PLACES



SKETCH "C" (8) PLACES





-----


-----



-----


-----

-----

-----







--	--	--	--	--	--



APPROVED

APPROVED

APPROVED

PUR. AGT. APPROVAL

